

SPECIFICATION

GALVANIZED STEEL STRUCTURAL PLATE

Scope: This specification covers the manufacture and installation of the galvanized steel structural plate structure detailed in the plans.

Material: The galvanized steel structural plate structure shall consist of plates and appurtenant items as shown on the plans and shall conform to the requirements of AASHTO M 167 / ASTM A 761. All manufacturing processes including corrugating, punching, curving and galvanizing shall be performed within the United States using raw materials made in the United States.

Assembly bolts and nuts shall be galvanized and meet the provisions of ASTM A 449, Type 1, and ASTM A-563, Grade C, respectively.

Assembly: The structure shall be assembled in accordance with the shop drawings provided by the manufacturer and per the manufacturer's recommendations. Bolts shall be tightened using an applied torque of between 100 and 300 ft.-lbs.

Installation: The structure shall be installed in accordance with the plans and specifications, the manufacturer's recommendations, and the AASHTO Standard Specifications for Highway Bridges, Section 26 (Division II).

Backfill: The structure shall be backfilled using clean well graded granular material that meets the requirements of AASHTO M 145 for soil classification A-1, A-2 or A-3. Backfill must be placed symmetrically on each side of the structure in 6 to 8 inch lifts. Each lift shall be compacted to a minimum of 90 percent density per AASHTO T 99.

Note: Construction loads that exceed highway load limits are not allowed on the structure without approval from the Engineer.



SPECIFICATION
GALVANIZED STEEL
STRUCTURAL PLATE

DRAWN BY: H.B.M.	REV. BY: J.A.D.	SCALE:
DATE: 12-06-95	DATE: 9-15-00	1009836E